

METHOD OF MEASURING ENTERING BEAM PARAMETERS OF THE CYCLOTRON U-240 STABLE ISOTOPE SEPARATOR

O. E. Valkov, O. V. Dubinin, O. K. Zaichenko

Method of measuring of the beam parameters at the entrance of the ion-optical tract of the cyclotron U-240 stable isotope separator is described.

Keywords: isotope separator, ion-optical tract, Twiss parameters, emittance.